

KOLHAPUR FOUNDRY AND ENGINEERING CLUSTER

Regd. Office: Plot P 62, Shirol MIDC, Kolhapur
Email: kfcuster@gmail.com, goshima.sr@gmail.com
+ 91 9970132921, +91 8668993902.

Detail Tender Notice and Technical Specification

FOR SUPPLY OF HOT AIR SUCTION BLOWER

Kolhapur Foundry and Engineering Cluster invites Sealed tenders from reputed manufacturers and suppliers having past experience in similar type of works for Manufacturing, Supplying, grouting and Erection of following equipment for, **Thermal Sand Reclamation Plant, Plot P-82, at MIDC Gokul Shirgaon Kolhapur.**

Hot Air Suction Blower

Last date of submission of sealed tender is 13.11.2018 up to 4.00 p.m.

The General Condition and Technical Specifications are as below.

General Conditions

1. The Rates shall be including of all fittings, Fixtures, installation, transportations, loading and unloading.
2. The taxes will be extra as per standard rates to be quoted by the Bidder.
3. The Bid shall be submitted in TWO Envelops systems. Envelope 1 shall contain the Bio data of the bidder, Company Profile, and Technical details and specifications of the material / Equipment and Envelope 2 shall contain the financial bid. E.M.D. in form of Demand draft amounting Rs. 10,000/- drawn in favor on "*Kolhapur Foundry and Engineering Cluster*" payable at Kolhapur shall be enclosed in Envelope 1 .
4. The Owner reserves the right to accept or rejects any or all the offers without giving any reasons.
5. The Bidder to submit all Technical specifications, along with the quote.
6. The bidder shall provide all civil foundation drawing, all type of electrical work drawings etc.
7. Last Date of submission is 13.11.2018 up to 4.00 PM.
8. The seal tender/quotations will be received at **Sand Reclamation Plant Office, Plot P 82, Gokul Shirgaon MIDC, Kolhapur on or before 13.11.2018 from 11.00 am to 04.00 pm. (except Monday and Public Holidays).**
9. The Bidder can post or submit by hand the tenders at said address.
10. Tenders/quotations sent by post, by registered post and must reach by the above time and date. For late delivery or no delivery by postal authority, the Owner will not be responsible.
11. The tenders will be opened on the same date if possible or any other Pre-intimated Date, in the presence of such intending tenderer's or his / their authorised representatives who may be present at that time.

Technical Details

- 1) Supply, Installation , grouting of Hot Air Suction Blower ...

Blower Details :-

Motor - C.G. make only, Air flow – 8400 M³/ Hrs, Pressure – 300 mmWc , Temp. – 450 Degree

Fan details :

Impeller :- SS-304

Casing :- SS-410

- 2) Manufacturing, Supply , Installation , grouting & testing of 6 mm Thick Cyclone assly. with Rotary Air Lock valve , 2 meter above the ground level.
- 3) Manufacturing , Supply , Installation & testing of M.S. ducting line , ID 500 X 4 mm Thk X 40 Mtrs long & M.S. ducting line , ID 300mm X 4 mm Thk X 10 Mtrs long.
- Both lines should covered with 2 inch thermal insulation with Aluminium sheet ducting.

For more technical assistance you may please contact to Mr. Amar Alugade, Manager Operational of Thermal Sand Reclamation Plant, Plot P 82, Gokul Shirgaon MIDC on his cell no. + 91 8668993902.

**SD/-
Chairman,
Kolhapur Foundry and Engineering Cluster
Regd. Office: Plot P 62, Shirol MIDC, Kolhapur.
+91 9970132921.**
