

HEAD OFFICE : "Udyog Sarthi", Mahakali Caves Road,  
Andheri (E), Mumbai - 400 093.

FORT BRANCH : Orient House, 5th Floor,  
Adi Marjaban Street, Billard Estate, Fort, Mumbai - 38.  
Tele : 2687 0027/52/54/73 Fax : (022) 2687 1587  
Tele : 2261 6547 Fax : (020) 2261 6548



No. MIDC/Fire/ 1464/14  
Date: 16/06/2014

M/s. Kolhapur Foundry and Engineering Cluster Ltd.,  
Plot No.P-62, MIDC,  
Shiroli Indl. Area,  
Kolhapur.

Sub.-Grant of "Provisional No-Objection Certificate" for your proposed construction of Plant building on Plot No.P-62, MIDC, Shiroli Indl. Area, Kolhapur.

Ref.- Your application on single window vide No. SWC/87/1/20140514/277628 dated 14.05.2014 for Provisional NOC

Dear Sir,

This has reference to your application under reference above. This office has "No Objection Provisional" for your proposed construction of Plant building on Plot No.P-62, MIDC, Shiroli Indl. Area, Kolhapur, having built-up area admeasuring 1721.78 Sq. Mtrs. The area wise details of proposed constructions are as under:

Sr. No.	Name of the area	Built up area in Sq. Mtrs.	Occupant Load No. of Persons
1.	Main building	1123.6	112
2.	Extra HEight	561.80	
3.	Toilet Block	27.38	-----
4.	Security Cabin	9.00	-----
	<b>Total Built up area.</b>	<b>1721.78</b>	<b>112</b>

Marginal Open Space For Plot above 5000 Sq. Mtrs As per table no 10 of D C Rules.

Sr. No.	Plot Size in Sq. m.	Minimum Open Space from front side	Minimum Marginal Open Space from other sides
1.	Above 5001 sq. m.	9 m. or 1/3 <sup>rd</sup> height of building whichever is more.	9 m. or 1/3 <sup>rd</sup> height of Building whichever is more.

This N.O.C. is valid subject to fulfillment of the following conditions.

Following Provisions of Maharashtra Fire Prevention and Life Safety Measures Act, 2006

- Under **Section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.
- As per the provision as **under :- 10** of the said Act. No person other than the License Agency shall carry out the work of providing Fire Prevention and Life Safety Measures or performing. Such other related activities required to be carried out in any place or building or part thereof provided that,
  - No Licensed Agency or any other person claiming to be such Licensed Agency shall give a certificate under **sub-section (3)** of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance. (It is mandatory to submit fire prevention and fire protection drawings prepared by license agency. List Of Licensed Agencies is Available on the Website:- [www.mahafireservices.gov.in](http://www.mahafireservices.gov.in) & Go to e-License)

