

MAHARASHTRA INDUSTRIAL DEVELOPMENT CORPORATION

(A Government of Maharashtra Undertaking)

HEAD OFFICE : "Udyog Sarathi" Marol Indl. Area, Mahakali Caves Road,
Andheri (E), Mumbai - 400 093
Tele : (022) 2687 0052 / 52 / 54 / 27 / 73 Fax : (022) 26871587

PRINCIPAL OFFICE : 4, 4 (A), 12th Floor, World Trade Centre, Complex I,
Cuffe Parade, Mumbai - 400 005.
Tele : (022) 22151451 / 52 / 53 Fax : (022) 22188203
Website : www.midcindia.org, www.maharashtrairtparks.com
Email - feedback@midcindia.org



॥ उद्यमात् सकल समृद्धि ॥

MIDC

No. MIDC/Fire/ 3252/14
Date: 25/10/2014

M/s. Kolhapur Foundry and Engineering Cluster Ltd.,
Plot No.P-62, MIDC,
Shiroli Indl. Area,
Kolhapur.

Sub.:- Grant of "Revised Provisional No-Objection Certificate" for your proposed expansion/construction of plant buildings on Plot No. P-62, MIDC, Shiroli Indl. Area, Kolhapur.

Ref.:- 1. This office Prov. NOC No. MIDC/Fire/1464, dated 16/06/2014
2. Application submitted by the company on single window vide letter No. SWC/87/1/20140514/277628 dated 14/05/2014.

Dear Sir,

With reference to your application, this office has "No-Objection (Revised Provisional)" for your proposed contraction of Plant buildings on Plot No.P-62, MIDC, Shiroli Indl. Area, Kolhapur. having built up area admeasuring 2806.46 Sq. Mtrs. The area wise details of constructions are as under:

Sr. No.	Name of the Area	Area in Sq. Mtrs.	Occupant Load
01.	Main building Ground Floor	1066.72	--
02.	Extra Height	533.36	--
03.	Open To Sky Platform	1170.00	--
03.	Toilet Block	27.38	--
04.	Security Cabin	9.00	--
Total Built up Area		2806.46	--

Marginal Open Space For Plot above 5000 Sq. Mtrs As per table no 10 of D C Rules.

Sr. No.	Plot Size in Sq. Mtrs.	Minimum Open Space from front side	Minimum Marginal Open Space from other sides
1.	Above 5001 Sq. Mtrs.	9 Mtrs. or 1/3 rd height of plant whichever is more.	9 Mtrs. or 1/3 rd height of Plant whichever is more.

This N.O.C. is valid subject to fulfillment of the following conditions: -

Following Provisions of Maharashtra Fire Prevention and Life Safety Measures Act, 2006

- Under **Section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.
- As per the provision as **under: - 10** of the said Act. No person other than the License Agency shall carry out the work of providing Fire Prevention and Life Safety Measures or performing such other related activities required to be carried out in any place or building or part thereof provided that,
 - No Licensed Agency or any other person claiming to be such Licensed Agency shall give a certificate under **sub-section (3)** of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof

